

MODEL NUMBERS	MUZ-GL25VGD MSZ-GL25VGD	MSH-09RV MUH-09RV	PERCENTAGE INCREASE
Nominal Cooling Capacity (kW)	2.5	2.5	
EER (Cooling)	5.1	2.63	93.9%
Nominal Heating Capacity (kW)	3.2	3.1	
COP (Heating)	4.85	3.2	51.6%
MODEL NUMBERS	MUZ-GL35VGD MSZ-GL35VGD	MSH-12RV MUH-12RV	PERCENTAGE INCREASE
Nominal Cooling Capacity (kW)	3.5	3.4	
EER (Cooling)	4.12	2.58	59.7%
Nominal Heating Capacity (kW)	3.7	4	
COP (Heating)	4.57	2.86	59.8%
MODEL NUMBERS	MUZ-GL50VGD MSZ-GL50VGD	MSH-18RV MUH-18RV	PERCENTAGE INCREASE
Nominal Cooling Capacity (kW)	4.8	5.1	
EER (Cooling)	3.62	2.41	50.2%
Nominal Heating Capacity (kW)	5.4	5.4	
COP (Heating)	3.7	2.7	37.0%
MODEL NUMBERS	MUZ-GL60VGD MSZ-GL60VGD	MSH-24RV MUH-24RV	PERCENTAGE INCREASE
Nominal Cooling Capacity (kW)	6	6.3	
EER (Cooling)	3.77	2.31	63.2%
Nominal Heating Capacity (kW)	6.8	6.4	
COP (Heating)	4.07	2.38	71.0%
MODEL NUMBERS	MSZ-GL71VGD MUZ-GL71VGD	MSH-26SV MUH-26SV	PERCENTAGE INCREASE
Nominal Cooling Capacity (kW)	7.1	7.2	
EER (Cooling)	3.53	2.52	40.1%
Nominal Heating Capacity (kW)	8	8	
COP (Heating)	3.83	2.85	34.4%
MODEL NUMBERS	MSZ-GL80VGD MUZ-GL80VGD	MSH-30SV MUH-30SV	PERCENTAGE INCREASE
Nominal Cooling Capacity (kW)	7.8	8.1	
EER (Cooling)	3.31	2.33	42.1%
Nominal Heating Capacity (kW)	9	8.9	
COP (Heating)	3.53	2.54	39.0%

EER – Energy Efficiency Ratio (EER) is a measure of system efficiency at a given set of rating conditions. It is a ratio calculated by dividing the cooling capacity in kW by the power input in kW.

COP (Coefficient of Performance) – the ratio of the refrigerant effect (refrigeration capacity) to the work done by the compressor - the higher the number, the more efficient the system.

Air conditioners with a higher EER and COPS value are more efficient. Therefore when we are comparing COP and EER values of two products with the same in the same capacity range, it allows us to determine which product is more energy efficient.

EER is used to indicate performance ratio in cooling.
COP is used to indicate performance ratio in heating.

EER and COP Values are calculated at Test conditions based on AS/NZS3823.1.1 as per below.

Cooling: Indoor Dry-bulb temperature 27°C Wet-bulb temperature 19°C.
Outdoor Dry-bulb temperature 35°C Wet-bulb temperature 24°C.

Heating: Indoor Dry-bulb temperature 20°C.
Outdoor Dry-bulb temperature 7°C Wet-bulb temperature 6°C.

MSZ-GL42 excluded as it does not have a comparative product from 2002.